



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1325

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Apton Partioning Limited

Unit 3, Cannon Business Park,
Gough Road, Coseley,
West Midlands,
WV14 8XR

Tel: 01902 385250

Who fabricate the following timber fire doors and or doorsets:

**Vicaima FD30, Vicaima FD60.
Halspan FD30.**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The frame specification and field of application for the doors to achieve from **30 minutes to 60 minutes integrity** are detailed on page 2 of this certificate. Fire doors manufactured at factory reference: A-AB9

First Issued: 04 April 2018
Reissued: 04 December 2023
Valid to: 14 December 2028
Issue No: 6

Ian Woodhouse
Head of Technical – IFC Certification
Kiwa Ltd

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/Test Report
Vicaima	FD30	FEA/F99112A
Vicaima	FD60	Chit/A13093
Halspan	FD30	Chilt/A12061

Signed on behalf of Kiwa Ltd



Ian Woodhouse
Head of Technical – IFC Certification
Kiwa Ltd

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.