



FIRE RESISTANT GLAZED PARTITION SYSTEMS

Certificate number: IFCC 1876

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Apton Partitioning Limited

**Unit 3 Cannon Business Park
Gough Road
Coseley
West Midlands
WV14 8XR, UK**

Who fabricate the following:

Quartz Single & Double Glazed Fire Rated Glass Partitioning System

have successfully completed the requirements of the SDP 21 (Partitions) scheme. This includes the testing of products to **BS 476: Part 22: 1987** the inspection of their Factory Production Control and continuing surveillance assessments and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes integrity** is detailed in page 2 of this certificate.

Initial Certification: 21 December 2023

Valid to: 21 December 2028

Issue number: 1

Ian Woodhouse
Head of Technical – IFC Certification
Kiwa Ltd

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire-resistant glazed partitioning systems are manufactured in accordance with assessment/ test reports referenced within the following table:

Description	Fire Rating	Assessment/Test Report
Apton Quartz Partition System	30 mins	PAR/19596/01
Apton Quartz DG Glass door	30 mins	WF 413194
Apton Quartz DG Timber door	30 mins	WF 413193
Apton Quartz SG Double Timber Doors	30 mins	WF 502181
Apton Quartz SG Glass door	30 mins	WF 436181
Apton Quartz SG Glass Only	30 mins	CFR1003161

Signed on behalf of Kiwa Ltd



Ian Woodhouse
Head of Technical – IFC Certification
Kiwa Ltd

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.